

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-0026:203 Page 1 of 1

CATEGORY: Speakers

LISTEE: Simplex, *100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul D. Mattern (978) 731-8542

DESIGN: Model 4903-9xxx speaker/strobes. Suffixes xxx may be 106 through 121, 106H through 109H, 126 through 133, 126H, 127H, 136 through 147, 142H, 144H, 146H, 155 through 178, 168H, 171H, 174H, 301 through 306, 301H, 303H, 305H, 313 through 336, 326H, 329H, or 332H. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as speaker/strobes for use with separately listed compatible fire alarm control units. All versions are intended for indoor use. Models 4903 -9118 through 9121, -9132, 9133, -9155, -9157, -9159, -9161, -9163, -9165, -9313, -9315, -9317, -9319, -9321, and -9323 are intended for ceiling mount use. All other versions are intended for wall mount only. Also suitable for the hearing impaired applications.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager